



Certificate of Compliance

This certificate is issued for the following:

Polyethylene (PE) Pipe for Underground Fire Protection Service

SDR 7, 9 and 11 in sizes 2 through 24 inch
(See table on next page)

Prepared for:

WL Plastics Corp
3575 Lone Star Circle Suite 400
Fort Worth, Texas 76177
USA

Manufactured at:

WL Plastics Corp
2151 West Park Road
Elizabethtown, KY 42701
USA

FM Approvals Class: 1613

Approval Identification: 0003060216

Approval Granted: June 5, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller".

David B. Fuller
VP, Manager - Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group



Certificate of Compliance

Product Designation	O.D., Pipe Size, in. / mm	Pressure Rating, psi (kPa)	Remarks
Class 200 DR 11 Pipe	2, 3, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24 in.	200 (1380)	a, b, c
Class 200 DR 11 Pipe	50, 63, 75, 90, 110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630 mm	200 (1380)	a, b, c
Class 250 DR 9 Pipe	2, 3, 4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24 in.	250 (1725)	a, b, c
Class 250 DR 9 Pipe	50, 63, 75, 90, 110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630 mm	250 (1725)	a, b, c
Class 335 DR 7 Pipe	4, 6, 8, 10, 12, 14, 16, 18, 20, 22, 24 in.	335 (2310)	a, b, c
Class 335 DR 7 Pipe	110, 125, 140, 160, 180, 200, 225, 250, 280, 315, 355, 400, 450, 500, 560, 630 mm	335 (2310)	a, b, c

Remarks:

- a. Pipe and fittings may be directly connected together by the butt fusion process. Manufacturer's fusion instructions must be strictly followed for a proper fusion joint.
- b. The diameter basis is IPS & DPS sizes.
- c. Ideal Blue pipe Approved



Member of the FM Global Group