

# CERTIFICATE

<b>Certificate holder</b>	<b>Bänninger Kunststoff-Produkte GmbH Bänningerstr. 1 35447 Reiskirchen GERMANY</b>
<b>Production facility</b>	Staßfurt
<b>Product</b>	Pressure pipes made from PP-RCT (Polypropylene Random-Copolymer) for installation
<b>Nominal diameter</b>	Outside diameter 180 mm up to 355 mm
<b>Classification</b>	EG 110
<b>Testing basis</b>	DIN EN ISO 15874-2:2004-03 Certification scheme ZP 10.25.1/8 (2013-02)

**Mark of conformity**



**Registration No.** P1R0370

**Valid until** 2018-10-31

**Right of use** This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.

See annex for further information.

2013-10-21  
Robert Zorn M.Sc.  
Managing Director

A handwritten signature in black ink, appearing to be 'R. Zorn', is written over a horizontal line.



# ANNEX

<b>Certificate</b>	P1R0370 dated 2013-10-21
<b>Technical Data</b>	Material: PP-RCT  Type: see production facility related material list  Diameter: 180 mm up to 355 mm  Colour: - green, similar to RAL 6024 - customer related colour coding according to company standard specification  Weldable with: - Pipes and Fittings PP-R according to DIN EN ISO 15874 and ZP 10.25.1/8 - Multilayer pipes PP-RCT / AL / PP-RCT according to ZP 9.18.1 - Multilayer pipes PP-RCT / PP-RCT-GF / PP-RCT according to DIN EN ISO 21003-2 and ZP 9.12.1
<b>Testing laboratory/ Inspection body</b>	IMA Materialforschung und Anwendungstechnik GmbH Labor für Kunststoffprüfung Wilhelmine-Reichard-Ring 4 01109 Dresden
<b>Test report(s)</b>	B212/13.1 dated 2013-07-11

